

**PLUMBING & GAS PIPING
CERTIFICATION PRESSURE TEST
Okanogan County Building Department**



VISUAL SYSTEM
INSPECTION IS REQUIRED

VISUAL SYSTEM
INSPECTION IS REQUIRED

123 North 5th Ave- Rm # 115
Okanogan, WA 98840

Phone: (509) 422-7110
Fax: (509) 422-7220

Building Owner _____ Permit # _____
Address _____ Date of Test _____
Contractor _____ License # _____

<input type="checkbox"/> Ground Work		<input type="checkbox"/> Rough Plumbing		<input type="checkbox"/> LPG Gas Piping	
DWV		WATER SERVICE		LPG GAS PIPING	
Air	PSI		PSI		PSI
Water	Head		Working Pressure		
Time	Minutes		Minutes		Minutes

<input type="checkbox"/> Hydronic	
	PSI
	Minutes

MINIMUM TEST REQUIREMENTS PER THE IRC & UPC

Air Test-- 5 PSI -- 15 Minutes	Air Test-- 50 PSI -- 15 Minutes	Air Test -- 3 PSI -- 10 Minutes
Water Test-- 10' Head --15 Minutes	Test At Working Pressure 50 PSI-- 15 Minutes	
Hydronic -- 100 PSI--15 Minutes		

I hereby certify the information provided above is the result of the plumbing system pressure test conducted by the undersigned at indicated address and date. Misrepresentation of this certification is a gross misdemeanor under RCW 9A.72.040 subject to a two statute of limitation.

Signature _____ Date _____